

TAMILNADU FIRE - RESCUE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE

R.C No : 242 / V / TVT / 2023

Date: 04.08.2023

NOC No : 40 / 2023

Sub : Fire and Rescue Service - Fire and Rescue Station Thiruvottiyur – Issuing Of No Objection Certificate – Functioning the School

Ref : 1. G.O/ M.s 122 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

2. G.O/ M.s 122 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

3. Application Received from Correspondent of SMT.MOHINI SAROGI VIVEKANANDHA VIDYALAYA. Dated: 28.07.2023.

Based on the reference in the G.O's cited (1) & (2) Mr. D. PARGUNAN Station Officer Thiruvottiyur, Inspected the school in the name of SMT.MOHINI SAROGI VIVEKANANDHA VIDYALAYA. NO.148/7,8,9,10, ,149/3A1,3A4pt,151/1,2, IV STREET, JOTHI NAGAR, THIRUVOTTIYUR, CHENNAI – 600019. on 28-07-2023. Here I issue this NO OBJECTION CERTIFICATE subject to the condition noted there on and such conditions as may be prescribed. The Fire Fighting Equipment were found to be in position and Regular licence has to be obtained from the competent authority.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire safety systems should be maintained in Good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per sq. Meter as per national Building code-2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As per Para 6.3 of the BIS standards IS 14435 : 1997 if the classrooms have only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipment's.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Sub – Urban District at Ambattur.

OFFICE SEAL WITH DATE



To

**SMT.MOHINI SAROGI VIVEKANANDHA VIDYALAYA,
NO.148/7,8,9,10, ,149/3A1,3A4pt,151/1,2, IV STREET, JOTHI NAGAR,
THIRUVOTTIYUR,CHENNAI – 600019.**

STATION OFFICER
FIRE – RESCUE STATION
THIRUVOTTIYUR, CHENNAI – 600 019

Copy to:

1. The District Officer (Chennai – Sub - Urban),
TamilNadu Fire & Rescue Service, Chennai – 58.